

## Broadband Middle Mile & Carrier Neutral Location



### Addendum #1

Issue Date: March 13<sup>th</sup>, 2023  
Bids Due: **March 17<sup>th</sup>, 2023**  
Time: 1:30 PM  
Location: Civic Center  
325 E. Aspen Ave.  
Fruita, CO 81521

---

The items contained in this Addendum are hereby issued to provide more information about the project. This Addendum shall include the following enclosed items:

Answers to questions received before the cutoff date,

### Question/Answer Section:

1. Q. Please confirm whether the CNL is desired to be attached to the existing Public Works building, or free-standing.  
A. The CNL should be free-standing in the northeast corner of the site with an access off Kiefer Ave.
  
2. Electrical:  
Q. Please confirm whether the CNL is desired to have its own dedicated electrical service (as opposed to feed from the PW building).  
A. Yes, we anticipate a separate electrical service for the CNL.  
  
Q. Please confirm desired electrical service size/type (200A single phase?).  
A. Yes, 200A service, single phase should be sufficient.
  
3. Generator:  
Q. What size generator is desired? (50 kW?)  
A. Yes, 50 kW generator is what we want.  
  
Q. Please confirm that generator is desired to be natural gas, as indicated by the “gas feeder” line of the BOM.  
A. Yes, it is the intent that a natural gas generator is used with a new gas service.
  
4. Access Control  
Q. On the BOM, please clarify the difference between scope to be covered under Line 6 (Access Control) under Carrier Neutral Location and Lines 1 & 2 under Building Access.  
A. The building access would be the access from the road (Kiefer Ave.) including an approach driveway and any fencing necessary to enclose the site and separate it

from the rest of the City Shops facility. Access control would be how the building is secured via automated door locks, etc.

Q. Is there a particular system desired (perhaps already in use by the City) for access control, or is selection up to the design-builder?

A. The rest of the city uses primarily keyed locks or a keypad lock. We don't have a system in place and would defer to the design-build recommendation.

Q. Are all 144 fibers to be terminated at the FTP in the CNL?

A. Yes.

### **End of Question/Answer Section**

The Contractor shall acknowledge receipt of this, and any future Addenda by signing the first page and including in the response. This Addendum **DOES NOT** change the deadline to submit a bid.