

Broadband Middle Mile & Carrier Neutral Location



Addendum #2

Issue Date: March 15th, 2023
Bids Due: **March 17th, 2023**
Time: 1:30 PM
Location: Civic Center
325 E. Aspen Ave.
Fruita, CO 81521

The items contained in this Addendum are hereby issued to provide more information about the project. This Addendum shall include the following enclosed items:

Answers to questions received before the cutoff date,

Question/Answer Section:

1. Can the handholes be plastic T-22 rated instead of concrete?
 - A. Yes, if the handhole is outside of traffic areas.
2. Can the Town confirm that the placement of the CNL will be in the northeast corner of their property?
 - A. Yes, it is in the northeastern most portion of the City Shops yard.
3. Do any on-site improvements need to be considered by the bidder for access to the CNL building on town property? (i.e. fencing, separate access control, new driveway, etc.)
 - A. Yes, the thought is that this facility would have its own access off Kiefer Ave. with and new driveway and gate. If access to this facility is required all the way around the building, then new fencing connecting to the north and east fence lines will be required. A new driveway apron will also be required.
4. Can the Town confirm there is an electric meter and gas meter either on-site or nearby to the new CNL building?
 - A. We would anticipate a new electric and gas meter separate for this facility. There is electric lines running overhead to a certain point along Kiefer before it goes underground. Gas is also available in Kiefer Ave.
5. Will optional line items be considered for the bid? (i.e. 2-post racks vs. 4-post enclosed racks for last mile providers? 4" HDPE for the railroad bore, etc.)

Yes, it is the intent that the response be a turnkey project. If there are items that do not show up in the BOM, then it would be anticipated that the contractor would include those in this response.

End of Question/Answer Section

The Contractor shall acknowledge receipt of this, and any future Addenda by signing the first page and including in the response. This Addendum **DOES NOT** change the deadline to submit a bid.